

SAIFEL VERIFICATION REPORT
AT SRF LTD, INDORE ON TR1 ON 16TH AND 17TH FEB 2007

SAIFEL SYSTEMS WAS SWITCHED ON AND OFF FOR CERTAIN TIME PERIOD
RESULTS OF WHICH ARE AS UNDER:

Saifel ON		
Time in secs		KWHunits
122		0.030
60		0.015
60		0.015
60		0.015
15		0.005
60		0.018
60		0.018
60		0.018
15		0.005
15		0.005
60		0.018
15		0.005
30		0.009
59		0.018
14		0.005
30		0.009
59		0.018
60		0.014
60		0.014
120		0.029
60		0.014
1094		0.297

Saifel OFF		
Time in secs		KWHunits
15		0.005
60		0.018
30		0.009
60		0.018
15		0.005
60		0.018
15		0.005
30		0.009
62		0.018
120		0.036
60		0.018
60		0.018
15		0.005
15		0.005
60		0.018
60		0.015
60		0.015
120		0.030
62		0.015
63		0.015
1042		0.295

Unit Consumption

per Second: 0.00027148 Saifel On

0.00028311 Saifel Off

Savings in KwH Units: **4.11 %**

for SRF Ltd,

for Saif Electronics Ltd

Auth Sign. 

Auth Sign. 

Abha
17-02-07
Ananya
17/2/07

SRF LIMITED

Block-C Sector-45
Gurgaon 122 003
Haryana India
Tel. : +91-124-4354400
Fax : +91-124-4354500
Website : www.srf.com

Regd. Office :

A-16, Aruna Asaf Ali Marg
Qutab Institutional Area
New Delhi 110 067 India

SRF LIMITED

Indore Special Economic Zone
Sector 3 Pithampur 454 775
Dist. Dhar (MP) India
Tel: +91-7292-400526
Fax: +91-7292-401753