



BSES Limited

Supply Division :

Post Bag 6808
Electricity House
Santacruz (East)
Mumbai - 400 055
Phone : 610 05 05
Fax : 022 - 611 28 58/617 09 94
Gram : SUBELEC

No. R&D / 48 / 2002-2003

October 14, 2002

M/s SAIF Electronics Ltd,
174 Hira Bldg, 1st Floor,
Carnac Road,
Opp Crawford Market,
Mumbai - 400002


Kind Attn: Mr M Rangwala

Dear Sir,

This refers to the installation of 5th harmonic filter fabricated by you, at our Consumer Centre building. With the installed filter measured percentage reduction in fifth harmonic component of current observed was of the order of 64.87 to 77.42 % which was found satisfactory.

Thanking you,

Yours faithfully,


(Ricky Uchil)
Mgr(R&D)